

Appendix 1

Note: Mirant may request, subject to Department approval, additional complying scenarios to be added to the table at a later date.

Summary of Complying Ib SO₂/MMBtu Rates

			3-hr	24-hr
1a	3 & 4	Both Units @ 16 hrs max/ 8 hrs min	0.46	0.44
1b	3 & 4	Both Units @ 12 hrs max/ 12 hrs min	0.46	0.42
2a	3 & 5	Both Units @ 16 hrs max/ 8 hrs min	0.51	0.47
2b	3 & 5	Both units @ 12 hrs max/ 12 hrs min	0.49	0.45
3a	4 & 5	Both Units @ 16 hrs max/ 8 hrs min	0.50	0.45
3b	4 & 5	Both units @ 12 hrs max/ 12 hrs min	0.45	0.43
4a	1,2,3	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 3 @ 16 hrs max/ 8 hrs min	0.37	0.40
4b	1,2,3	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 3 @ 12 hrs max/ 12 hrs min	0.37	0.40
5a	1,2,4	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 4 @ 16 hrs max/ 8 hrs min	0.40	0.40
5b	1,2,4	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 4 @ 12 hrs max/ 12 hrs min	0.40	0.40
6a	1,2,5	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 5 @ 16 hrs max/ 8 hrs min	0.46	0.43
6b	1,2,5	Units 1,2 @ 8 hrs max/ 8 hrs min/ 8 hrs off; Unit 5 @ 12 hrs max/ 12 hrs min	0.46	0.43
7a	3,4,5	All units @ 16 hrs max/ 8 hrs min	0.33	0.30
7b	3,4,5	All units @ 12 hrs max/ 12 hrs min	0.32	0.29
7c	3,4,5	All units @ 8 hrs max/ 16 hrs min	0.30	0.26

Assumes Background Concentrations

3hr: 238.4